

| | | |
|--|--|--|
| | <p>Item No. 13</p> <p>June 18, 2018</p> <p>ss</p> | <p><i>feasibility but also the economic viability and the environmental sustainability of CETP, even on a small to moderate scale, we recommend that:</i></p> <ol style="list-style-type: none"> <i>a) The industries should be required to recover water and reuse it from the tertiary treated effluent instead of discharging into the river.</i> <i>b) CETP-VI should adopt multi stage Reverse Osmosis System (RO Plant), of adequate capacity for recovery of water and its reutilization by the member units of CETP, followed by RO reject management system such as Multi Effect Evaporator, and residual salt management.</i> <i>c) The CETP management should also prevent the river and land from any damage from the RO reject generated from CETP.</i> <i>d) CETP-II, III and IV should also be upgraded to incorporate a tertiary treatment system together with the multi stage Reverse Osmosis System (RO Plant) of adequate capacity for reuse and reutilization of treated water along with the reject management system such as Multi Effect Evaporator, and residual salt management.</i> <i>e) The individual industries should periodically monitor the quality of effluent discharged from the primary treatment facilities for smooth and efficient operation of CETPs, and should comply with the consent conditions.”</i> <p>He is further directed to inform as to whether the deficiencies pointed out by the Committee, have been rectified or not. He shall send complete report to the Tribunal before 05th July, 2018. He shall also prepare an Action Plan for rectifying the deficiencies, after giving a time frame. The earlier order passed by the Tribunal in respect of the respondent industry/CETP not to discharge any untreated water into the river or any open place and the treated water should be made use of by the unit itself and for that purpose proper action plan be prepared, shall continue.</p> |
|--|--|--|

| | | |
|--|--|--|
| | <p>Item No. 13</p> <p>June 18, 2018</p> <p>ss</p> | <p>List this part-heard matter on 05th July, 2018.</p> <p>.....,JM (Raghuvendra S. Rathore)</p> <p>.....,EM (Dr. Satyawan Singh Garbyal) (18.06.2018)</p> |
|--|--|--|

