



जोधपुर नगर निगम, (दक्षिण)



पोलोटैक्निक कॉलेज परिसर, रेजीडेन्सी रोड, जोधपुर

E-Mail-nnjelectrical@gmail.com

क्रमांक :- एफ.14/रो./कार्य/2023/RL-12648

दिनांक :- 23/01/2023

:- सिमित निविदा सूचना :-

U.B. No.....

जोधपुर नगर निगम दक्षिण की ओर से निम्नालिखित सिमित निविदा सूचना कार्य करने हेतु आमंत्रित की जाती है। जो इन्छुक संवेदक निविदा में हिस्सा लेना चाहते है वे निविदा प्रपत्र दिनांक 27.01.2023 को प्रातः 11:00 बजे तक प्राप्त कर उसी दिन 02:00 बजे निविदा खोली जायेगी।

विस्तृत विवरण व शर्तों के लिए नगर निगम कार्यालय से जानकारी प्राप्त की जा सकती है।

कंसं	कार्य का नाम	अनु.लागत	निविदा प्रपत्र मूल्य	कार्य करने की अवधि
01	जी-20 सम्मेलन के तहत विभिन्न मार्गों पर लगे विद्युत पोल एवं अन्य पर कलर का कार्य।	0.50	200/-	01 माह
02	मनोनित पार्षद ईदु खां जी मेहर की अनुशंषा पर लाईट लगाने का कार्य।	0.50	200/-	01 माह

यह निविदा वेबसाईट www.sppp.raj.nic.in एवं <https://Urban.rajasthan.gov.in/MCJS> व jodhpurmc.org पर देखी जा सकती हैं।

क्रमांक :- एफ.14/रो./कार्य/2023/RL-12649 to 12651
प्रतिलिपि :-

1. लेखाधिकारी नगर निगम, (दक्षिण), जोधपुर।
2. बिल लिपिक, नगर निगम, (दक्षिण), जोधपुर।
3. नोटिस बोर्ड, नगर निगम, (दक्षिण), जोधपुर।

Raj Singh
अधिसाषी अभियन्ता (वि.)
नगर निगम (दक्षिण)जोधपुर
दिनांक :- 23/01/2023

अधिसाषी अभियन्ता (वि.)
नगर निगम (दक्षिण), जोधपुर

Nagar Nigam (South), Jodhpur

①

Name of work:- Supply and Fixing of Tri Color rope light on Tp/Oct pole JMC South

Estimate

Part A ("H" Schedule)

S.N.	CODE No	PARTICULARS	QTY.		RATE		AMOUNT
1		Paint of existing Tublar pole , Oct Pole and Other with two coat color, including required ladder in all respect as per site condition and as per direction of engineering incharge.	1	job		Per Job	

Drip Singh
XEN(Elect)
JMC

I/We agree to do the aboveH-Schedule Item No. 1 Each with JMC terms conditions.

Signature of Contractor

JODHPUR MUNICIPAL CORPORATION JODHPUR (SOUTH)

Name of Work:- Supply and fixing of LED Light in various location in Nagar Nigam south Zone (Ward 01 to 37)

RUIDP SOR 2022

"G" Schedule.

S.N	PARTICULARS	Qty	Unit	Rate	Unit	Amount
1	E18130 0 Providing & Fixing of IK07 IP 66 protected LED Street Light Luminaire on existing bracket/pole. Fixture made of powder coated single piece pressure die cast aluminum LM6/ ADC12 material with heat dissipation fins on housing with UV stabilized PC/Toughened Glass cover (UV stablization report submitted for UV cover) and secondary lens on each LED & should be SMD type . The System level Luminaire efficacy >=120 lm/ wt with High Power LEDs is to be used and potted driver must be potted & has a unique BIS R number with Input Voltage AC 120 to 270 V AC with High voltage Cutoff @>=300 V AC and Auto resetting Safety ,Input Frequency 50Hz±3% Power Factor >0.95 driver Efficiency >85% ,THD(I) <10% Humidity 10% to 90% RH Working Temp -5C to 45C . driver current <1000mA shown in LM79 report. The luminaire shall be BIS certified and T.C. certified. Life Expectancy Equal or more than 50000 burning hrs with Minimum 70% lumen maintained ,color Rendering Index >70 and CCT 5700K +355K. Surge protection shall be min ≥ 4 KV internal and min 10 KV external. driver should be Phase to phase protection of 440 V for 4 Hrs. Manufactures Word Mark/Name Engraved/Embossing on die cast housing to allow raceability/authenticity. Fixture shall be AS PER IS 10322 Complianced. OEM Must have its own in house NABL lab setup for all testing facilities for LED fixtures. (LM79/LM80) Certificate/ report with liable warranty of product/accessories from OEM shall be submitted. All as per pre approved by Engineer in charge. For additional technical parameters of products/ work , refer Annexure "A" attached with this BSR.					
	E18130 LED Street Light fixture 45 Watt	1	Nos	4405.00	Each	4405.00
	E18130 LED Street Light fixture 70 Watt	8	Nos	5250.00	Each	42000.00
2	E18170 0 Providing & Fixing of Street light bracket made out from following size of ' B ' class , Medium class G.I. Pipe confirming to IS : 1239 P - 1 (2004) with heavy duty pole clamp, Saddles suitable fastners etc. as required. All as per pre approved by Engineer in charge. For additional technical parameters of products/ work , refer Annexure "A" attached with this BSR					
	E18170 32 mm Dia.	9	RM	279.00	Mtr.	2511.00
3	E04050 0 Supply & drawing Wiring for sub mains as per PWD specification for electrical Works with ISI marked (IS:694) , 1100 Volts grade PVC insulated flat twin core sheathed solid aluminium conductor with 10 SWG G.I. Support wire duly clipped including all as per pre approved by Engineer in charge, making connections, as required. OEM Must have its own in house NABL lab setup for all testing facilities for wires. For additional technical parameters of products/ work , refer Annexure "A" attached with this BSR					
	E04050 4.0 sq.mm	27	RM	39.00	Mtr.	1053.00
Total G Schedule						49969.00

J. En.(Elc)

Ex. En. (Elc)

I/We agree to do the above "G" Schedule (Part A) work @.....above/below on RUIDP 2022/BSR Electric 2022with JM terms and conditions.

Signature of Contractor