



**Government of Rajasthan
Office of Project Director**

Rajasthan Urban Infrastructure Development Project

AVS Building, Jawahar Circle, JLN Marg, Jaipur - 302017

Tel No.: 141 2721966, Fax No.: 141 2721919, email : mailruidp@gmail.com, mail.ruidp@rajasthan.gov.in
web site : www.ruidp.rajasthan.gov.in

F3 (106) (32)/RUSDIP/PMU/CMS/2007/ 1733

Dated: 8/5/14
04.2014

Sub: Construction Management System: Circular – 82

Ref: Guidelines for Protection of Service lines and Water Meter.

Installation of Domestic Water Meters is a very important loan covenant under the agreed Loan Covenants and the targets have to be achieved. Following guidelines should be followed during installation of water meter:

1. The service connection lines should be laid in such a manner that it should not create any inconvenience/obstruction to the habitants.
2. Water connection should be made properly using required appropriate fittings like ferrule, bends, elbows, nipples, tees etc. The connecting pipe should not be hanging/loose and must be properly embedded /clamped in the wall/ floor/ ground.
3. Primarily water meter should be installed at safe place with due protection.
4. If safe place is not available and installed at vulnerable place then water meter should be protected from damage or theft by putting appropriate mechanism such as MS box or constructing small chamber with locking arrangements etc. as per requirement of site. Such Box/ Chamber should have proper opening for meter reading & its replacement.

This circular is equally applicable to all members of PMU, IPIU, IPMC & DSC.

M. S. Kumar
(Ambrish Kumar, IAS)
Project Director

F3 (106) (32)/RUSDIP/PMU/CMS/2007/ 1734 72

Dated: 8/5/14
04.2014

Copy to the following for information and compliance;

1. PA to PD, PMU, Jaipur.
2. Addl. PD / ACE (T)/ FA / Dy. PD (Adm.)/ Dy. PD (NLCP)/SE (Co-ord)/ SE (WW)/ (WS) / (Roads)/ (Bridges)/ PO. (all)/ CAO / All APOs / AAO/ RUIDP, Jaipur.
3. Zone SE, RUSDIP, Jaipur/Jodhpur/Kota.
4. Executive Engineer, IPIU, RUSDIP Alwar, Baran-Chhabra, Barmer, Bharatpur, Bundi, Chittorgarh, Churu, Dhaulpur, Jaisalmer, Jhalawar-Jhalarapatan, Karauli, Nagaur, Rajsamand, Sawai Madhopur and Sikar.
5. Team Leader IPMC, Jaipur/ DSC-I, Jaipur/ DSC-II, Jodhpur/ DSC-III, Kota, RUSDIP.
6. ACP, RUIDP, Jaipur to send by e-mail and put up the Guidelines on the website.

Superintending Engineer (IV)