


Sub: Construction Management System: Circular – 60

Ref: Guidelines for third party inspection of Rubber rings in various Water Supply and Waste water sector sub-projects of RUIDP.

It has been observed that Rubber ring is an important component of waste water and water supply pipe line works. The EE, IPIUs are required to satisfy themselves on the basis of test certificates issued by the vendor/manufacturer for the rubber rings procured from different sources. To further ensure the quality of the rubber rings, these shall be got inspected by third party inspection agency, irrespective of the bid condition in accordance to the IS 5382.


The norms laid down in relevant IS Code no. 5382-1985 (amended up to date) of specification for rubber sealing rings for gas mains, water mains and sewers should be referred for procurement of Rubber rings by EE, IPIU.

All concerned EE, IPIU are directed to ensure the same and inform the contractor accordingly.


(Vaibhav Galriya)
Project Director

Copy to following for information and necessary action:

1. Addl. PD / CE (T)/ FA / Dy. PD (Adm.)/ Dy. PD (NLCP)/SE (Co-ord)/ SE (WW)/ (WS) /(Roads)/ (Bridges)/ PO (all)/ Sr. AO / All APOs / AAO/ PA to PD PMU, RUIDP, Jaipur.
2. Zone SE, RUSDIP, Jaipur/Jodhpur/Kota.
3. Executive Engineer, IPIU, RUSDIP, Alwar, Baran, Barmer, Bharatpur, Bundi, Chittorgarh, Churu, Dholpur, Jaisalmer, Jhalawar-Jhalrapatan, Karauli, Nagaur, Rajsamand, Sawai Madhopur, Sikar.
4. Team Leader IPMC, Jaipur/ DSC-I, Jaipur/ DSC-II, Jodhpur/ DSC-III, Kota, RUSDIP.
5. Dy. TL/ACM, DSC-I, Alwar/ Dholpur/ Karauli/ Sawai Madhopur, Dy. TL/ACM, DSC-II, Churu/ Jaisalmer/ Barmer/ Sikar and Dy. TL/ACM, DSC-III, Chittorgarh/ Rajsamand/ Bundi/ Baran, RUSDIP.
6. ACP, RUIDP, Jaipur to send by e-mail.


Chief Engineer (T)